

HC Facilities Department – # of Critical Asset Failures - Corrections/Public Safety Facilities

Performance Measure

Number of critical asset failures by building.

Objective

The goal is to not have any.

Analysis

Justice Center – ACD3 Electric Failure , Hot Water Boot –Failure

Kitchen Hood fire suppression, Dom. Pumps

Hillcrest – PAK-5 at Rec.

Juvenile Youth Center - Major Chiller Repair, Boiler #1 Replacement

Aux. Building.

Coroners - DNA Area - A/C problems, Com Center A/C & Electric

250 WHT Major Chiller Problem (Re-builds / Replacement)

Building	Safety Systems	Building Systems	Building Envelope	Total
1100	1	3	0	4
0246	0	1	0	1
2020	0	2	0	2
Aux	0	4	0	4

